

ORDINANCE NO. 545, N.S.
 AN ORDINANCE OF THE CITY OF
 EL PASO DE ROBLES ADOPTING AN
 AMENDMENT TO ORDINANCE 515 N.S.
 TO ESTABLISH A REQUIREMENT FOR INSTALLATION
 OF A EMERGENCY AUXILIARY ELECTRICAL
 DISCONNECT.

Section IV. **Changes or additions to the National Electrical Code.**
 The following addition to the National Electrical, is hereby
 adopted:

B. In all new construction and remodels involving 50% or more of the total square footage of the building, when the required disconnect is located within the building or in an area not readily accessible, an emergency disconnect shall be provided in a readily accessible location on the exterior of the building as designated by the Fire Chief. The disconnecting device shall be located within an approved security enclosure (such as a Knox Box) and a key provided the Fire Department.

PASSED AND ADOPTED THIS 16th day of February, 1988 by the
 following roll call vote:

AYES:	Cousins, Dolan, Martin and Russell
NOES:	None
ABSENT:	Ovitt
ABSTAIN:	None

Nick Russell
 MAYOR NICK RUSSELL

ATTEST:

Jerry Bankston
 CITY CLERK, JERRY BANKSTON

AAB257